

**OFFICE OF THE EXECUTIVE ENGINEER, DIVISION NO. II,
JAMMU DEVELOPMENT AUTHORITY, JAMMU.**

No:-JDA/II/Corri/2017-18/42

Dated:- 25-07-2017

CORRIGENDUM

Name of work:- Supply, Installation, Testing and commissioning of Solar Lighting system including 5 years AMC at Maharaja Hari Singh Ji Park, Jammu.

Type of Solar Light



Stand alone Solar Street Lighting Systems with 35 WP module, 15W LED, lithium ion battery of 12V, 5.2 AH and minimum 1000 cycles, 4 mtrs. Pole (above GL) with dimming facilities.

Reference:- e -NIT No. JDA/II/e-NIT/2017-18/31 dated 12-07-2017.

1. Please read in Terms and Conditions Serial No.10 " MNRE (G.O.I.)" instead of "M&RE",
2. Please read in Technical Specifications (Broad Performance Specification) Light out put :- "Peak lux level at 4 mtrs. Height: 30 in 3 hours of full light on" instead of "Peak lux level at 4 mtrs. Height: 21 in 3 hours of full light on".
3. Please read in Mechanical Components item No.vi read:- " The lamp housing should have water proof(IP-65) and should be painted with a corrosion resistant paint" Instead of " The lamp housing should have be water proof and should be painted with a corrosion resistant paint".

All other terms and conditions of the NIT shall remain unchanged.

No: JDA/II/2317-25
Dt. 25-7-2017.


Executive Engineer,
Division No. II, JDA,
Jammu. 

Copy to the:-

1. Vice Chairman, Jammu Development Authority Jammu for kind information.
2. Superintending Engineer, JDA for kind information.
3. Financial Advisor and CAO, JDA for kind information.
4. Executive Engineer JDA Division No. I, for information.
5. Asstt. Ex-Engineer, JDA Electric Sub Division for information.
6. Sr. Programmer, JDA for information.
7. President Contractor Association, Jammu for information.
- 8/9 Head Draftsman/Asstt. Accounts Officer, JDA Division No. II Jammu.